Ministry of the Environment
Ontario

The Ontario Water Re

WATER WELL RECORD

1. PRINT ONLY IN SPACES PROVIDED
2. CHECK ☒ CORRECT BOX WHERE APPLICABLE

COUNTY OR DISTRICT	TOWNSHIP, BOROUGH, CITY, TOWN, VILLAGE	CON., BLOCK, TRACT, SURVEY ETC	LOT
PARRY SOUND	MACHAR	2, PLAN 57	26427 LOT 24

OWNER (SURNAME FIRST)	ADDRESS	DATE COMPLETED
MAYHEW DEL	SOUTH RIVER	DAY 28 MO 08 YR 89

LOG OF OVERBURDEN AND BEDROCK MATERIALS (SEE INSTRUCTIONS)

GENERAL COLOUR	MOST COMMON MATERIAL	OTHER MATERIALS	GENERAL DESCRIPTION	DEPTH - FEET FROM	TO
BROWN	SAND			0'	12'
GREY	ROCK			12'	325'

WATER RECORD

WATER FOUND AT - FEET	KIND OF WATER
320	☒ FRESH ☐ SULPHUR ☐ SALTY ☐ MINERALS ☐ GAS
	☐ FRESH ☐ SULPHUR ☐ SALTY ☐ MINERALS ☐ GAS
	☐ FRESH ☐ SULPHUR ☐ SALTY ☐ MINERALS ☐ GAS
	☐ FRESH ☐ SULPHUR ☐ SALTY ☐ MINERALS ☐ GAS
	☐ FRESH ☐ SULPHUR ☐ SALTY ☐ MINERALS ☐ GAS

CASING & OPEN HOLE RECORD

INSIDE DIAM INCHES	MATERIAL	WALL THICKNESS INCHES	DEPTH - FEET FROM	TO
6 1/4	☒ STEEL ☐ GALVANIZED ☐ CONCRETE ☐ OPEN HOLE ☐ PLASTIC	.188	+1.5	20
6	☐ STEEL ☐ GALVANIZED ☐ CONCRETE ☒ OPEN HOLE ☐ PLASTIC		20	325
	☐ STEEL ☐ GALVANIZED ☐ CONCRETE ☐ OPEN HOLE ☐ PLASTIC			

SCREEN

SIZE(S) OF OPENING (SLOT NO.)	DIAMETER INCHES	LENGTH FEET
MATERIAL AND TYPE	DEPTH TO TOP OF SCREEN FEET	

PLUGGING & SEALING RECORD

DEPTH SET AT - FEET FROM	TO	MATERIAL AND TYPE (CEMENT GROUT, LEAD PACKER, ETC.)
		BENSEAL

PUMPING TEST

PUMPING TEST METHOD	PUMPING RATE	DURATION OF PUMPING
☒ PUMP ☐ BAILER	3 GPM	1 HOURS 10 MINS

STATIC LEVEL	WATER LEVEL END OF PUMPING	WATER LEVELS DURING ☒ PUMPING ☐ RECOVERY 15 MINUTES	30 MINUTES	45 MINUTES	60 MINUTES
15 FEET	250 FEET	250 FEET	250 FEET	250 FEET	250 FEET

IF FLOWING, GIVE RATE	PUMP INTAKE SET AT	WATER AT END OF TEST
GPM	275 FEET	☒ CLEAR ☐ CLOUDY

RECOMMENDED PUMP TYPE	RECOMMENDED PUMP SETTING	RECOMMENDED PUMPING RATE
☐ SHALLOW ☒ DEEP	275 FEET	3 GPM

LOCATION OF WELL

IN DIAGRAM BELOW SHOW DISTANCES OF WELL FROM ROAD AND LOT LINE. INDICATE NORTH BY ARROW.



DRILLERS REMARKS

64686

FINAL STATUS OF WELL	☒ WATER SUPPLY ☐ OBSERVATION WELL ☐ TEST HOLE ☐ RECHARGE WELL ☐ ABANDONED, INSUFFICIENT SUPPLY ☐ ABANDONED, POOR QUALITY ☐ UNFINISHED ☐ DEWATERING
WATER USE	☒ DOMESTIC ☐ STOCK ☐ IRRIGATION ☐ INDUSTRIAL ☐ OTHER ☐ COMMERCIAL ☐ MUNICIPAL ☐ PUBLIC SUPPLY ☐ COOLING OR AIR CONDITIONING ☐ NOT USED
METHOD OF CONSTRUCTION	☐ CABLE TOOL ☐ ROTARY (CONVENTIONAL) ☐ ROTARY (REVERSE) ☒ ROTARY (AIR) ☐ AIR PERCUSSION ☐ BORING ☐ DIAMOND ☐ JETTING ☐ DRIVING ☐ DIGGING ☐ OTHER

CONTRACTOR

NAME OF WELL CONTRACTOR: J. MARSHALL & SON	WELL CONTRACTOR'S LICENCE NUMBER: 3670
ADDRESS: EMSDALE ONT.	
NAME OF WELL TECHNICIAN: JACK MARSHALL	WELL TECHNICIAN'S LICENCE NUMBER: T-0587
SIGNATURE OF TECHNICIAN/CONTRACTOR: J. Marshall	SUBMISSION DATE: DAY 15 MO 09 YR 89

OFFICE USE ONLY

CONTRACTOR'S COPY

FORM NO. 0506 (11/80) FORM